

防爆構造電気機械器具型式検定合格証

Type Approval Certificate for Ex-Equipment

申請者 Applicant	Hans Turck GmbH & Co. KG Witzlebenstr. 7 45472 Mülheim an der Ruhr, Germany
製造者 Manufacturer	Werner Turck GmbH & Co. KG Goethestraße 7 58553 Halver, Germany
品名 Equipment	Control and Distribution Cabinets
型式の名称 Type Identification	Control and Distribution Cabinets EG-VA *****/**_****/**. ****
防爆構造の種類 Type of Protection	Ex “ia”, “ib”, “ic”, Ex “mb”, “mc”, Ex “eb”, “ec”, Ex “nC”, “nA”, Ex “op is”, Ex “db”, Ex “tb”, “tc”
対象ガス又は蒸気の爆発等級 及び発火度 Equipment group, Temperature class and EPL	IIA/IIIB/IIC, T6/T5/T4/T3/T2/T1, Ga/Gb IIIA/IIIB/IIC, T135°C/T80°C /Da/Db
防爆記号 Ex marking	Ex eb db mb ib [ia Ga][op is Gb][op is Ga] IIA/IIIB/IIC T6/T5/T4/T3/T2/T1 Gb Ex tb [ia Da][op is Db][op is Da] IIIA/IIIB/IIC T135°C/T80°C Db Ex ec mc nA nC ic db eb mb ib [ia Ga][op is Gb][op is Ga] IIA/IIIB/IIC T6/T5/T4/T3/T2/T1 Gc Ex tc [ia Da][op is Db][op is Da] IIIA/IIIB/IIC T135°C/T80°C Dc [Ex ia Ga][Ex op is Gb][Ex op is Ga] IIA/IIIB/IIC [Ex ia Da][Ex op is Db][Ex op is Da] IIIA/IIIB/IIC
適用基準 Applicable standards	JNIO SH-TR-46-1:2020, JNIO SH-TR-46-2:2018 JNIO SH-TR-46-6:2015, JNIO SH-TR-46-8:2015 JNIO SH-TR-46-8:2020, JNIO SH-TR-46-7:2018 JNIO SH-TR-46-11:2020, JNIO SH-TR-46-9:2018 JNIO SH-TR-46-5:2018
定格 Rating	See user manual
使用条件 Specific condition of use	Yes, see user manual
レポート番号 Report number	557 / JPEX 0004.00 / 24
型式検定合格番号 Certificate Number	TÜV 24 JPEX 0004 X
有効期間 Duration of Validity	From 2025.01.28 To 2028.01.27
型式検定者の所属及び氏名 Section and name of the approver	Klauspeter Graffi
同一型式 Variants	N/A

機械等検定規則による型式検定に合格したことを証明する。

The Equipment passed the Type Approval according to the inspection rule for machinery.

発行日
Date of certificate

2025 年 01 月 28 日
(YYYY.MM.DD)

型式検定実施者
Certified by

テュフ ラインランド インダストリー サービス GmbH
TÜV Rheinland Industrie Service GmbH



Klauspeter Graffi

(Type and signature of responsible person)